



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BR5802

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	PCS Innotec International N.V. Schans 4, B-2480 Dessel
Distributor <i>Vertreiber</i>	PCS Innotec International N.V. Schans 4, B-2480 Dessel
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
Model <i>Modell</i>	Thread Seal
Test Reports <i>Prüfberichte</i>	laboratory control test: 16/012/5146/01 from 29.02.2016 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 09.06.2021 / 16-0386-GNV
Ablaufdatum / AktENZEICHEN

08.07.2016 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Thread Seal	class: H	for dimensions > DN 10 up to DN 50

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

permit for: metallic screwed joints for application for coarse threads
not allowed: in gas installation according to DVGW-TRGI 2008

DVGW